

Energy Report Summary for November 2010

Prepared for:



Natural Resources
Canada

Ressources Naturelles
Canada

Canada

Prepared by:



*Science Applications International Corporation
(SAIC Canada)*


December 21, 2010
Document Version 1.0
CM002171

PROPRIETARY

Drake Landing Solar Community Energy Overview for September 2010

This document summarizes the energy generated and used within the Drake Landing Solar Community at Okotoks Alberta.

Additional Information may be found here: <http://www.dlsc.ca>



System Energy Diagram

| Table 0-1 Summary for September 2010 | | |
|--|-------------------|---------------------------|
| Description | This Month | Since July 1, 2010 |
| Total Incident Solar Energy | 659.7 GJ | 5443.1 GJ |
| Total Solar Energy Collected | 155.3 GJ | 1781.8 GJ |
| Total Solar Energy Delivered to STTS | 155.8 GJ | 1708.1 GJ |
| Total Energy Delivered to BTES | 33.0 GJ | 1241.2 GJ |
| Total Energy Extracted from BTES | 240.5 GJ | 308.2 GJ |
| Total Energy Delivered from STTS to HX-2 | 375.2 GJ | 665.7 GJ |
| Total Solar Energy Delivered to District Loop | 344.6 GJ | 593.3 GJ |
| Natural Gas Energy Used | 31.0 GJ | 31.0 GJ |
| Boiler Thermal Energy Delivered to the District Loop | 28.0 GJ | 28.0 GJ |
| Total Energy Delivered to District Loop | 372.6 GJ | 621.3 GJ |
| Average Solar Collector Efficiency | 17 % | 33 % |
| Average Efficiency of HX-1 | 100 % | 96 % |
| Average Efficiency of HX-2 | 92 % | 89 % |
| Average BTES core temperature | 59.4 °C | 59.6 °C |
| Electrical energy used | 8.6 GJ | 33.1 GJ |
| PV energy generated | 0.4586 GJ | 5.4 GJ |
| Net change in energy stored in STTS | -9.37 GJ | -31.4 GJ |
| Solar Fraction | 92 % | 95 % |